



This document has been prepared by OBS GRAPHICS, KOLKATA, INDIA. This document is exclusive property of OBS GRAPHICS. Unauthorized communication or reproduction is prohibited.

OBS GRAPHICS						1	
	DATA SHEET OF ALARM VALAVE	PREPARED	MB	DOC. NO.: OBS/AV/01			2
		CHECKED	KM	CONTRACT NO.:			3
		APPROVED	PB	SHEET	1 OF 1		4
		DATE		EQPT. NO.			5
CLIENT:			PROJECT:			6	
SERVICE: FIRE HYDTANT & SPRINKLER SYSTEM		OPERATING MODE: CONTINIOUS / INTERMITTENT		SITE:		7	
LOCATION: INDOOR / OUTDOOR		AREA CLASSIFICATION: HAZARDOUS / NON HAZARDOUS				8	
NUMBER REQUIRED: AS PER BILL OF QUANTITIES						9	
ALARM VALAVE						10	
	TECHNICAL PARAMITERS	DESCRIPTION				14	
A	CODE/STD	UL / FM LISTED				15	
1	RATED WORKING PRESSURE	12.3 KG / CM2				16	
2	END CONNECTION	FLANGED, DRILLING AS PER IS: 1538				17	
3	MOUNTING	VERTICALLY				18	
4	FACTORY HYDRAULIC TEST PRESSURE	25 KG / CM2				19	
5	FINISH	FIRE RED EPOXY PAINTED				20	
6	ACCESSORIES	CONSTANT PRESSURE TRIM, DRAIN VALVE, WATER MOTOR GONG, PRESSURE GAUGE, STOP VALVE.				21	
7	APPROX WEIGHT WITH OUT TRIM	59 KG				22	
8	MATERIAL OF CONSTRUCTION					23	
9	HOUSING & COVER PLATE	CI, CONFORMING TO IS: 210 GR. 260				24	
10	SEAT, CLAPPER, BUSH.	BRONZE; IS: 318, LTB-II				25	
11	GASKET, VALVE SEAT.	NEOPRENE RUBBER				26	
12	HINGE PIN, CLAMP	SS 304				27	
13	BOLT	MS: IS: 1363				28	
14	MAKE	H.D.FIRE / KOLEY				29	
15	APPROVAL	TAC APPROVED				30	
						31	
G.A. DRG. NO.		VENDOR				32	
FLOW DIAG. NO.		VENDOR DRG. NO.				33	
PLANT LAYOUT DRG. NO.		FOUNDATION DRG.NO.				34	
SUPPORT DRG. NO.		CALCULATION SHEET NO.				36	
ORDER NO.						35	
						36	
						37	
						38	
						38	
						40	
P0	ISSUED FOR APPROVAL	OBS	PB			41	
REV	DESCRIPTION	BY	APPROVED	CLIENT APP	DATE	42	