



This document has been prepared by OBS GRAPHICS, KOLKATA, INDIA. This document is exclusive property of OBS GRAPHICS. Unauthorized communication

OBS GRAPHICS						1	
	DATA SHEET OF BALL VALVE	PREPARED	MB	DOC. NO.: OBS/BV/01			2
		CHECKED	KM	CONTRACT NO.:			3
		APPROVED	PB	SHEET	1 OF 1		4
		DATE		EQPT. NO.			5
CLIENT:			PROJECT:			6	
SERVICE: FIRE HYDANT & SPRINKLER SYSTEM		OPERATING MODE: CONTINUOUS / INTERMITTENT		SITE:		7	
LOCATION: INDOOR / OUTDOOR		AREA CLASSIFICATION: HAZARDOUS / NON HAZARDOUS				8	
NUMBER REQUIRED: AS PER BILL OF QUANTITIES						9	
BALL VALVE						10	
TECHNICAL PARAMITERS		DESCRIPTION				14	
A	CODE/STD					15	
1	TYPE	FULL BORE 2 PIECE DESIGN.				16	
2	SIZE	25 NB / 15 NB				17	
3	PRESSURE CLASS	CLASS-II				18	
4	FLUID TO BE HANDLED	COLD WATER.				19	
5	WORKIONG PRESSURE	7.0 KG/CM ²				20	
6	CONSTRUCTION FUTERS	GM - LTB GR - II				21	
7	END CONNECTION	SCREWED TAPERED INTERNAL CONFIRMING TO IS: 554				22	
8	MODE OF OPERATION	HAND WHEEL				23	
9	MATERIAL OF CONSTRUCTION					24	
10	BODY, SEAT RING.	G.M. IS: 318 (LTB-II), CHROME FINISHED				25	
11	HAND WHEEL	CAST IRON FG 200 TO IS: 210				26	
12	BALL	TEFLON.				27	
13	HYDRAULIC TEST PRESSURE	21 KG/CM ²				28	
14	MAKE	ZOLOTO / LAKSHMI / UTTAM				29	
15	APPROVAL	TAC APPROVED / ISI MARKED				30	
						31	
G.A. DRG. NO.		VENDOR				32	
FLOW DIAG. NO.		VENDOR DRG. NO.				33	
PLANT LAYOUT DRG. NO.		FOUNDATION DRG.NO.				34	
SUPPORT DRG. NO.		CALCULATION SHEET NO.				35	
ORDER NO.						36	
						37	
						38	
P0	ISSUED FOR APPROVAL	OBS	PB			39	
REV	DESCRIPTION	BY	APPROVED	CLIENT APP	DATE	40	