

This document has been prepared by OBS GRAPHICS, KOLKATA, INDIA. This document is exclusive property of OBS GRAPHICS Unauthorised c

OBS GRAPHICS						1		
	DATA SHEET OF FIRE BRIGADE INLET (3-WAY)	PREPARED	MB	DOC. NO.: OBS/FBI/01			2	
		CHECKED	KM	CONTRACT NO.:			3	
		APPROVED	PM	SHEET	1 OF 1		4	
		DATE		EQPT. NO.				5
CLIENT:			PROJECT:				6	
SERVICE: FIRE HYDRANT & SPRINKLER SYSTEM			OPERATING MODE: CONTINUOUS / INTERMITTENT		SITE:	7		
LOCATION: INDOOR / OUTDOOR			AREA CLASSIFICATION: HAZARDOUS / NON HAZARDOUS			8		
NUMBER REQUIRED: AS PER BILL OF QUANTITIES						9		
FIRE BRIGADE INLET (3-WAY)						10		
	TECHNICAL PARAMETERS	DESCRIPTION				11		
1	CODE / STANDERD	IS: 904				12		
2	TYPE	3 - WAY				13		
3	TYPE OF CONSTRUCTION	FABRICATED, FROM M.S. PIPE				14		
4	INLET	INSTANTENIOUS MALE COUPLING WITH INBUILT NON RETURN VALVE				15		
5	OUTLET	M.S. FLANGED DRILLING AS PER IS: 1538.				16		
6	MATERIAL OF CONSTRUCTIONS					17		
7	BODY	MS ERW AS PER IS: 1239, PART-1				18		
8	INLET	GM, IS: 318, LTB-II				19		
9	OUTLET	FLANGE & DRILLING AS PER IS: 1538.				20		
10	TEST PRESSURE	14 KG/ CM2				21		
11		ISI MARKED COUPLING / FR				22		
12	MAKE	GEI / NEWAGE				23		
						24		
G.A. DRG. NO.		VENDOR				25		
FLOW DIAG. NO.		VENDOR DRG. NO.				26		
PLANT LAYOUT DRG. NO.		FOUNDATION DRG.NO.				27		
SUPPORT DRG. NO.		CALCULATION SHEET NO.				28		
ORDER NO.						29		
						30		
						31		
						32		
						33		
						34		
P0	ISSUED FOR APPROVAL		OBS	PB		35		
REV	DESCRIPTION	BY	APPROVED	CLIENT APP	DATE	36		