


This document has been prepared by OBS GRAPHICS, KOLKATA, INDIA. This document is exclusive property of OBS GRAPHICS Unauthorized communication or reproduction

<b>OBS GRAPHICS</b>						
	<b>DATA SHEET OF PRESSURE GAUGE</b>	PREPARED	MB	DOC. NO.: OBS/PG/01		
		CHECKED	KM	CONTRACT NO.:		
		APPROVED	PB	SHEET	1 OF 1	
		DATE		EQPT. NO.		
CLIENT:			PROJECT:			
SERVICE: FIRE HYDANT & SPRINKLER SYSTEM		OPERATING MODE: CONTINUOUS / INTERMITTENT		SITE:		
LOCATION: INDOOR / OUTDOOR-		AREA CLASSIFICATION: HAZARDOUS /NON HAZARDOUS				
NUMBER REQUIRED: AS PER BILL OF QUANTITIES						
<b>PRESSURE GAUGE</b>						
	TECHNICAL PARAMITERS	DESCRIPTION				
1	CODE / STANDARD	AS PER IS: 3624				
2	TYPE	BOURDON TYPE				
3	ACCURACY % FSD	± 1% OF FSD				
4	SIZE OF DIAL MM.	150Ø WHITE DIAL				
5	RANGE KG/CM2	0-10 KG/CM2				
6	ADJUSTMENT	MICROMETER TYPE ZERO ADJUSTER				
7	OVER RANGE PROTECTION	25% OF SCALE RANGE (MINIMUM)				
d)	GRADUATION	KG/CM2				
9	MAX. WORKING PRESSURE	7.0 KG/CM2				
10	<b>MAKE</b>	H. GURU / FIEBIG.				
11	<b>MATERIAL OF CONSTRUCTION</b>					
a)	ENCLOSURE	WHETHER PROOF CAST ALUMINIUM.				
b)	MOVEMENT MATERIALS	NON FERROUS				
c)	SENSING MATERIAL	NON FERROUS				
d)	WINDOW COVER	TRANSPARENT GLASS				
12	CONNECTION	2-WAY BALL VALVE, 1/2" BSP				
13	ACCESSORIES PROVIDED	2-WAY BALL VALVE, 1/2" BSP				
14	<b>TESTING</b>					
a)	VISUAL	100% DIMENSIONAL				
b)	CALIBRATION TEST	100%				
15	APPROVAL	BIS / TAC				
G.A. DRG. NO.		VENDOR				
FLOW DIAG. NO.		VENDOR DRG. NO.				
PLANT LAYOUT DRG. NO.		FOUNDATION DRG.NO.				
SUPPORT DRG. NO.		CALCULATION SHEET NO.				
ORDER NO.						
P0	ISSUED FOR APPROVAL	OBS	PB			
REV	DESCRIPTION	BY	APPROVED	CLIENT APP	DATE	

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49

