



This document has been prepared by OBS GRAPHICS, KOLKATA, INDIA. This document is exclusive property of OBS GRAPHICS Unauthorized

OBS GRAPHICS						1		
	DATA SHEET OF SPRINKLER	PREPARED	MB	DOC. NO.: OBS/SPRL/01			2	
		CHECKED	KM	CONTRACT NO.:			3	
		APPROVED	PB	SHEET	1 OF 1		4	
		DATE		EQPT. NO.			5	
		CLIENT:			PROJECT:			6
SERVICE: FIRE HYDRANT & SPRINKLER SYSTEM		OPERATING MODE: CONTINUOUS / INTERMITTENT		SITE:		7		
LOCATION: INDOOR / OUTDOOR		AREA CLASSIFICATION: HAZARDOUS / NON HAZARDOUS				8		
NUMBER REQUIRED: AS PER BILL OF QUANTITIES							9	
SPRINKLER						10		
	TECHNICAL PARAMETERS	DESCRIPTION				11		
1	CODE/STD	UL - LISTED				12		
2	TYPE OF SPRINKLER	PENDENT, UPRIGHT & SIDE WALL TYPE.				13		
3	WORKING PRESSURE	2.0 KG. / CM ² (MAXIMUM).				14		
4	TEMP. RATING	68°C.				15		
5	END CONNECTION	1/2" BSPT				16		
6	K - FACTOR	80				17		
7	SENSING MATERIAL	EXPANDING FLUID ENCAPSULATED IN GLASS BULB.				18		
8	BULB DIA.	5 MM.				19		
9	BULB COLOUR	RED				20		
10	BODY MATERIAL	FORGED BRASS				21		
11	FINISH	CHROME PLATED				22		
12	MAKE	VIKING / TYCO / HD				23		
13	APPROVAL	UL. LISTED.				24		
							25	
G.A. DRG. NO.		VENDOR					26	
FLOW DIAG. NO.		VENDOR DRG. NO.					27	
PLANT LAYOUT DRG. NO.		FOUNDATION DRG. NO.					28	
SUPPORT DRG. NO.		CALCULATION SHEET NO.					29	
ORDER NO.							30	
							31	
							32	
							33	
							34	
							35	
P0	ISSUED FOR APPROVAL		OBS	PB			36	
REV	DESCRIPTION		BY	APPROVED	CLIENT APP	DATE	37	