



This document has been prepared by OBS GRAPHICS, KOLKATA, INDIA. This document is exclusive property of OBS GRAPHICS Una

OBS GRAPHICS						1	
	DATA SHEET OF Y- STRAINER	PREPARED	MB	DOC. NO.: OBS/YSTR/01			2
		CHECKED	KM	CONTRACT NO.:			3
		APPROVED	PB	SHEET	1 OF 1		4
		DATE		EQPT. NO.			5
CLIENT:			PROJECT:			6	
SERVICE: FIRE HYDANT & SPRINKLER SYSTEM		OPERATING MODE: CONTINUOUS / INTERMITTENT		SITE:		7	
LOCATION: INDOOR / OUTDOOR		AREA CLASSIFICATION: HAZARDOUS / NON HAZARDOUS				8	
NUMBER REQUIRED: AS PER BILL OF QUANTITIES						9	
Y- STRAINER						10	
1	TECHNICAL PARAMITERS		DESCRIPTION			14	
a	TYPE		Y - TYPE			15	
b	TYPE OF CONSTRUCTION		CAST BODY, BOLTED COVER,			16	
c	PERFORATION		30 MESH			17	
d	END CONNECTION		FLANGE, DRILLING AS PER IS: 1538.			18	
2	MATERIAL OF CONSTRUCTION					19	
a	BODY / COVER		CI, IS: 210, FG 260.			20	
b	SCREEN		SS: 304			21	
c	GASKET		RUBBER IS: 638 TYPE-B.			22	
d	TEST PRESSURE		14 KG/CM2			23	
3	MAKE		SANT / KOLEY / KALPANA			24	
						25	
G.A. DRG. NO.		VENDOR				26	
FLOW DIAG. NO.		VENDOR DRG. NO.				27	
PLANT LAYOUT DRG. NO.		FOUNDATION DRG.NO.				28	
SUPPORT DRG. NO.		CALCULATION SHEET NO.				29	
ORDER NO.						30	
						31	
						32	
						33	
						34	
						35	
PO	ISSUED FOR APPROVAL		OBS	PB		36	
REV	DESCRIPTION		BY	APPROVED	CLIENT APP	DATE	
						37	